



120 West Verbena Avenue
Foley, Alabama 36535
(251) 943-1266
Fax (251) 943-7432
www.cityoffoley.org

NOTICE OF KNOX® KEY BOX REQUIREMENT

2015 International Fire Code Section 506.1-506.2.: Where access to or within a structure or an area is restricted because of secured openings or where immediate access is necessary for life-saving or fire fighting purposes, the fire code official is authorized to require a key box to be installed in an approved location. The key box shall be of an approved type and shall contain keys to gain necessary access as required by the fire code official. An approved lock shall be installed on gates or similar barriers when required by the fire code official.

The operator (responsible person) of the building shall immediately notify the fire code official and provide the new key when a lock is changed or rekeyed. The key to such lock shall be secured in the key box.

Required Location

All commercial buildings with fire alarm and/or fire protection sprinkler systems are required to install a "Knox® Box Rapid Entry System" key box in an approved location. Entry keys/cards to all parts of the building are required to be placed in the key box and maintained in accordance with Section 506.2.

Order Information

Knox Box® key boxes can be ordered online at <http://www.knoxbox.com/>. Browse the Knox Box® key boxes that are available and choose the box that best fits your needs. Click on the "Online Purchase" link; enter the zip code for your area and click continue. Click on the button in front of "Foley Fire Dept. – 120 W. Verbena Ave. – Foley, AL (with your zip code)" and click continue. It is important to make sure that you click on Foley in this step because each municipality has a unique Knox Box® key.

If you have any questions or require additional information, please contact:

Office: 251-971-6028

Fax: 251-943-7432

Email: fireinspections@cityoffoley.org